



**NOTE:**

- TOP OF TOE ROCK AS SPECIFIED FOR DESIGN FLOW HEIGHT OR 2/3 BANK HEIGHT (MIN).
- ROCKWORK FOR THE PURPOSE OF ARMORING MUST NOT BE TOPSOILED.
- 50% MINIMUM OF 40MM MINUS GRADED ROCK TO A COMPACTIBLE EMBEDMENT LAYER
- ARMORING MADE UP MIXED 300MM MINUS ROCK (MUST BE ANGULAR QUARRIED ROCK).
- EXISTING WATERWAYS ONLY, NOT SUITABLE FOR DEVELOPER SITES

**CONCEPT ONLY  
NOT TO SCALE**

										TITLE ROCKWORK DRAWING BANK STABILISATION FOR BATTERS < 1 IN 1.5 (EXISTING WATERWAYS ONLY - NOT DEVELOPER SITES)		
A NOTATION AMENDMENTS		MW		MK		17/12/18	DRAFTER	DESIGNER	DESIGN MANAGER APPROVAL	PROJECT MANAGER APPROVAL	PROJECT DATUM	ORIGINAL SIZE
REV	DESCRIPTION	COMPANY	PROJECT OR WO NUMBER	DRAWN	ENG. CHECK	PR. MAN. APP'D	DRAFTING CHECK	ENGINEERING REVIEW			SCALE	
1												
										7251/08/101	A	
										CODE	MWC DRAWING NUMBER	REV